

## DECLARATION OF PERFORMANCE

in accordance with Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020

## Hilti Firestop Collar CFS-C P

No. Hilti CFS-C P

1. Unique identification code of the product-type:

Hilti Firestop Collar CFS-C P

2. Intended use:

Fire Stopping and Sealing Product for Penetration Seals, see UKTA - 22/0043 (31.03.2023)

| Pipe penetrations | Non-Insulated and insulated Plastic pipes |
|-------------------|---|
|                   | Composite pipes                           |

3. Manufacturer:

Hilti Corporation, Feldkircherstrasse 100, 9494 Schaan, Principality of Liechtenstein

4. UK Importer:

Hilti (Gt. Britain) Limited, No. 1 Circle Square, 3 Symphony Park, Manchester, England, M1 7FS

5. System of AVCP:

System 1

6. European Assessment Document: EAD 350454-00-1104

UKTA - see UKTA - 22/0043 (31.03.2023))

**UK Technical Assessment Body:** UL International (UK) Ltd.

UK Approved body/s: UL International (UK) Ltd., No 0843

## 7. Declared performance:

| Essential characteristic            | Declared performance | Harmonised technical specification / Method of verification  |
|-------------------------------------|----------------------|--|
| Reaction to fire                    | Class E              | EN 13501-1   |
| Resistance to fire                  |                      | EN 13501-2   |
| Air permeability                    |                      |  |
| Water permeability                  |                      |  |
| Content and/or release of dangerous |                      | Declaration of conformity by the manufacturer                |
| substances                          | see UKTA – 22/0043   |  |
| Mechanical resistance and stability | (31.03.2023)         | No performance assessed                                      |
| Resistance to impact / movement     | (01.00.2020)         | No performance assessed                                      |
| Adhesion                            |                      | No performance assessed                                      |
| Airborne sound Insulation           |                      | EN ISO 10140-1:2010+A1:2012+A2:2014, EN ISO 10140-2:2010 and |
|                                     |                      | EN ISO 717-1:2013  |
| Thermal properties                  |                      | No performance assessed                                      |
| Water vapour permeability           |                      | No performance assessed                                      |

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued in accordance with in accordance with Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, under the sole responsibility of the manufacturer identified above. Signed for and on behalf of the manufacturer by:

Markus Schneider

Head of BU Code, Approval & Regulation Business Unit Fire Protection

Hilti Corporation

Luca Sironi Head of Marketing Business Unit Fire Protection Hilti Corporation