

Confirmation

LEED

On 14 November 2014, Eurofins Product Testing A/S received a sample of a firestop plug with the product name:

CFS-CC

supplied by

Hilti Entwicklungsgesellschaft GmbH

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant CDPH testing standards (See test report no. 392-2014-00278701B).

The test results of the tested flooring indicate that the product qualifies for LEED v4 specifications on VOC emissions by complying with:


VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of CDPH-IAQ (California Department of Public Health, Feb 2010); and a TVOC below 0.5 mg/m³ in both office and class room.

18 February 2015



Maria Pelle
Chemist



Janne R. Norup
Chemist