

DECLARATION OF PERFORMANCE

according to Annex III of the Regulation (EU) Nr. 305/2011 (Construction Products Regulation)

Hilti Firestop Joint Spray CFS-SP WB (CW)

No. Hilti CFS-SP WB (CW)

1. Unique identification code of the product-type:

Hilti Firestop Joint Spray CFS-SP WB

2. Intended use:

Fire Stopping and Fire Sealing Product: Linear Joint and Gap, see ETA-11/0343 (26.11.2020)

Perimeter Seal	Perimeter Seal between rigid floor slabs and curtain walling
----------------	--

3. Manufacturer:

Hilti Corporation, Feldkircherstrasse 100, 9494 Schaan, Principality of Liechtenstein

4. System of AVCP:

System 1

5. European Assessment Document:

EAD 350141-00-1106

European Technical Assessment:

ETA-11/0343 (26.11.2020)

Technical Assessment body:

Österreichisches Institut für Bautechnik (OIB)

Notified body:


MPA-Braunschweig, No. 0761

6. Declared performance

Essential characteristic	Declared performance	Harmonised technical specification / Method of verification
Reaction to fire	Class E	EN 13501-1
Resistance to fire	See ETA-11/0343 (26.11.2020)	EN 13501-2
Air permeability		EN 1026
Water permeability		EAD 350141-00-1106
Content, emission and/or release of dangerous substances		EN 16516
Mechanical resistance and stability		EAD 350141-00-1106
Resistance to impact/movement		EOTA TR 001
Adhesion		EAD 350141-00-1106
Durability and serviceability		Type Y ₁
Cycling or perimeter seals for curtain walls	See ETA-11/0343 (26.11.2020)	EAD 350141-00-1106
Airborne sound insulation		EN ISO 10140-1

The performance of the product identified above is in conformity with the declared performances. This declaration of performance is issued in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:



Cynthia Mikhael
Product Manager
Business Fire Protection
Hilti Corporation



Martin Althof
Head of Quality
Business Fire Protection
Hilti Corporation

27.09.2021

DoP_de_03-03_00000002513_Hilti CFS-SP WB CW