

DECLARATION OF PERFORMANCE

according to Annex III of the Regulation (EU) Nr. 305/2011 (Construction Products Regulation)

Hilti Firestop Joint Spray CFS-SP WB (LJ)

No. Hilti CFS-SP WB (LJ)

1. Unique identification code of the product-type:

Hilti Firestop Joint Spray CFS-SP WB

2. Intended use:

Fire Stopping and Sealing Product for Penetration Seals, see ETA-12/0078 (01.12.2014)

Linear Joint and Gap Seals	Horizontal and vertical linear joints in rigid or flexible wall and rigid floor constructions
----------------------------	---

3. Manufacturer:

Hilti Corporation, Feldkircherstrasse 100, 9494 Schaan, Principality of Liechtenstein

4. System of AVCP:

System 1

5. European Assessment Document:

ETAG Nr. 026-1 und ETAG Nr. 026-3

European Technical Assessment:

ETA-12/0078 (01.12.2014)

Technical Assessment body:

Österreichisches Institut für Bautechnik (OIB)

Notified body:

MPA-Braunschweig, No. 0761

6. Declared performance

Essential characteristic	Declared performance	Harmonised technical specification / Method of verification
Reaction to fire	Class E	EN 13501-1
Resistance to fire	See ETA-12/0078 (01.12.2014)	EN 13501-2:2007+A1:2009, EN 1366-4
Water permeability		ETAG 026-3
Content and/or release of dangerous substances		European Council Directive 67/548/EEC- Dangerous Substances Directive and Regulation (EC) No 1272/2008
Mechanical resistance and stability		ETAG 026-3
Resistance to impact / movement		ETAG 026-3
Adhesion		ISO 11600
Airborne sound insulation		EN ISO 140-3/ 20140-10 / 717-1
Use category		Type Y ₁

The performance of the product identified above is in conformity with the declared performances. This declaration of performance is issued in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Cynthia Mikhael
Product Manager
Business Fire Protection
Hilti Corporation

Martin Althof
Head of Quality
Business Fire Protection
Hilti Corporation